Seria HIDROTEHNICA TRANSACTIONS on HYDROTECHNICS

Tom 56(70), Fascicola 2, 2011 Some Environment Aspects Regarding The Fly Ash Dump Monitoring Hetes Dorel¹, David Ioan², Badea Catalin³, Podoleanu Corneliu Eusebiu⁴

Abstract: Big quantities of fly ash and slag (industrial waste materials) are stored in enormous dumps causing serious environmental concerns like: heavy metals contamination of lands and water, occupy of vastest lands (ha), fly ash dispersing by wind blowing (with great discomfort for people) On the other hand, these deposits of fly ash are made in a big dump which represents a big construction. These construction needs to be monitored to settling-displacement, water infiltration, environment protection etc.

This paper presents some environment aspects regarding the fly ash dam settlements.

Keywords: fly ash, slag, environment protection, industrial waste, fly ash dam settlements

1. INTRODUCTION

In this moment the Timişoara Power Plant from Romania produce (only in the cold time) the dense slurry which is a mixture between fly ash and water with masses ratio = 1:1 (figure 1). This residual material has a usually density of 1.36 kg/dm³ and is pneumatic pumped to Utvin ash dump. The old transport technology which has it the power plant consist of a dense slurry which was a mixture between fly ash and water with masses ratio = 1:10. That dense slurry produced many environment problems.

In Timisoara Power Plant the fly ash is produced by burning of pulverized coal into a fired boiler and is collected from the flue gas by electrostatic devices as cyclones.



Fig. 1 The transportation of dense slurry into fly ash dump

The retion dam elements are obtained from base dam on border and division dam (in interior).

With storage capacity finish of slag and fly ash from base dam were necessary to banking the dam (on

border and division dump). From this reason of dam banking is possible to appear some problems regarding the stability of dam.

There are made site measurements of benchmark dam.

2. SITE MESUREMENTS

The defining parameters of fly ash dam are:

- settlement;
- environment protection.

The settlement dam is the parameter which shows us the construction response during the exploitation live under different loads and factors.

The environment protection is parameter which shows us the protection of people live against blowing of micro particle of fly ash.

^{1,2,3,4} "Politechnica" University of Timişoara, Department of Hydrotechnical Engineering, George Enescu Street, No.1A, Zip code 300022, Timisoara, Romania, E-mail:hetesdoru@yahoo.com

The environment protection is realized by using modern technical solution to produce dense slurry.

The settlement dam was observed from 1997 (benchmark).

Into table 1 there are presented the absolute altitude from 2006 to 2008 compared with 1997 which correspond to first dam banking.

The table 2 presented the settlements from 2006 to 2008 compared with 1997.


Table 1 The benchmark of fly ash dam


Point	1997	2006 altitude	2007 altitude	2008 altitude	Attention altitude	Alarm altitude
BT1	90.4498	90.4167	90.4000	90.4010	90.3448	90.2748
BT2	90.3953	90.3817	90.3650	90.3670	90.2903	90.2203
BT3	90.3996	90.3903	90.3850	90.3840	90.2946	90.2246
BT4	90.6927	90.6696	90.6650	90.6610	90.5877	90.5177


Table 2


The settlement of fly ash dam


Point	2006 settlement	2007 settlement	2008 settlement	Attention settlement	Alarm settlement
BT1	3.31	4.97	4.88	10.5	17.5
BT2	1.36	3.03	2.83	10.5	17.5
BT3	0.93	1.46	1.56	10.5	17.5
BT4	2.31	2.77	3.17	10.5	17.5
















BT3 bsolute altitude during of 3 year



BT3 Settlement distribution during of 3 years



Settlement distribution during of 3 years 20 17.5 settlement (cm) 15 10.5 10 3.17 2.77 5 2.31 0 2006 2007 2008 Attention Alarm year

BT4

3. MCONCLUSIONS

The modern technical solution which produces dense slurry at Timisoara Power plant made a good protection of environment

The settlements dam for all checking points was lower compared with attention (10.5 cm) and alarm (17.5 cm) values.

The settlements dam was growing from 2006 to 2008 year.

REFERENCES

[1] Raport de sinteză a comportării în timp a construcțiilor de la depozitul de zgură și cenușă UTVIN - CET SUD Timișoara, ISPE, Timisoara, 2009.

[2] C Badea., C. Bob, I Balcu., S. Dan, Buchman. I., Experimental Researches on Efficient Building Materials Made with Ultra Fine Fly Ash, Proceedings of the WSEAS International Conference on Recent Advances In Materials Science, Bucuresti, Romania, 7-9 November, 2008

[3] Used for Building Construction, WSEAS International Conference on Engineering Mechanics, Structures and Engineering Geology, TUNSIA, 3-6 May, 2010