

SIZING OF TECHNICAL NETWORKS OF URBAN UTILITIES SYSTEMS

Cornel Jura¹,

Silviana Brata²,

Dorin Jura³

Abstract - The review paper presents the general scope of technical engineering and optimization methods of the most important urban utilities facilities: water supply and gas distribution networks functioning in open circuits, heating and electrical distribution networks respectively, functioning in closed circuits.

From the previously undertaken studies, it comes out the version with the most favorable technical and economical exploitation conditions. In the case of large systems, two or even several versions are analyzed in order to determine the optimized solutions.

The paper illustrates the most important documentations sources and results obtained from using urban networks optimizations software, additionally, the optimization models of virtual transitions and the obtained outcomes are presented.

Keywords: technical networks, optimization methods, virtual transitions method

1. PRIORI STUDIES AND URBAN NETWORKS OPTIMIZATION METHODES

It mainly includes the consistent elements coming from the authors' long preoccupation for the urban facilities optimization, regarding on one hand the additional and modernization works undertaken to the existing systems, and on the other hand the newly installed networks in adverse areas, even the either of metropolitan areas or in adjacent localities having and the historical and cultural monuments, the green areas, the supply of needed electrical energy.

2. OPTIMIZATION METHODES OF TECHNICAL NETWORKS

2.1 Implementation of software programs

The software programs used for networks optimization were developed for an initial version between 1972-1988, as a result of the collaboration with other institutions: ICH Bucharest, ICEPEGA Bucharest, IPJ Timis, CPJ Tims, IGCL Timisoara, IPROTIM, IPJ Sibiu [77,78].

The software implementation leads to the following conclusions:

- for the software development, related issues to the graphs theory were used [21, 32, 71];
- the effective implementation in the PhD thesis of certain special mathematic models have confirmed the efficiency of the optimization procedure [2,5,25,51];
- the implementation of special software, having as purpose the production of top energy by hydroelectrical stations production optimization, respectively the optimisation of low-cost energy in steam power plants, brings a contribution in the

centralized systems. Prior studies are meant to determine the set of measures ensuring the optimal functioning of the systems, the minimal exploitation cost, the technical and technological exploitation conditions.

As far as the technical documentation is concerned, it includes the bibliography list on fields of studies such as: hydraulics [3,18,20,27,28,29,56,57, 58], water supply and water economy [17,32,34,35, 48,52,53,55,57], hydraulics technical applications [14, 19,59,60,67,76,77,78], water supply networks [2,23, 24,25,36,42,43,44,45,46,69,70,71], thermal networks [4,5,6,7,16,40,61,62], gas [9,11,12,14,26,39,41,69,73, 74], hydroenergetic [1,21,31,49,50,51,54,63,64,65,66, 68] and electrical networks [8,10,13,15, 22, 30, 33, 37, 38,75].

There must be also checked the execution conditions of magistral and service networks optimal tracks, the field's durability and stability in the case of underground networks, the aggressiveness of underground water, as well as the necessary protective steps, the use of new materials and modern technologies.

Equally important, there should be considered the equipments and functioning conditions of urban communication lines, the existing infrastructure a optimization of technical networks exploitation processes [6,21,35,36,45,46,49,51,66,67,68];

d). the comparison between the results obtained by virtual transitions method implementation, for the first time, in the optimization supply networks, confirms the accuracy of the developed methods;

e)the validity of the functional ring balancing of closed circuit networks, thermal and electrical networks is confirmed exclusively by use of standardized diameters, inferior to those determined in optimization, in the pipes/conductors wich are closer to the heating station/transformation station, and respectively the superior standard diameters, in the farther pipes/conductors.

.f). where it is not possible the comparison of the results obtained by the virtual transitions method with those obtained by the software program, they were compared with the results known from the references speciality problems collection, obtained with identical study data.

2.2. Application of virtual transitions general method

The first group of parameters considering virtual transitions is $L_j \sqrt{Q_j}$, where L_j represents the

^{1,2} Politehnica " University of Timisoara, HISGA Department, G. Enescu Str. No. 1/A, Zip Code 300022, Timisoara, ³ Municipal Council Timisoara

length of the pipe and Q_j is the pipe's calculation flow, was applied for sizing the gravitational transportation pipes [35], for optimization applications of arborescent networks, and according to the latest studies [47], generally for systems whose cost is determined by a strictly ascending function depending on any of the pipes' diameter.

The virtual transitions general method, elaborated by Mosnin, consists of introducing a virtual flow $X=1$ into a closed loop network, determining then its distribution in the optimized closed loop network with the values x_j for all pipes in the network. In the first

translations, the parameters x_j were named "virtual flows", which created confusions because of the improper term. The correct names are appreciated to be „sizing parameters" and are defined by the relationship (1) for water and thermal networks,

$$x_j = \frac{D_j^{\alpha+m}}{EQ_p Q_j^2}, \quad (1)$$

(2) for gas networks,

$$x_j = \frac{d_j^{\alpha+m}}{Eq_{v0} q_{vj}^2} \quad (2)$$

and (3) for electrical networks

$$x_j = \frac{s_j^{\alpha+m}}{EI_o I_j} \quad (3)$$

where:

α is the exponent of the diameter/section in the relation of the pipe/conductor unitar cost;

m is the exponent of the diameter/section in the relation of the energy losses;

Q_p is the pumped flow in the system;

Q_j are the balanced flows of the j pipes;

q_{v0} is the total flow in the system;

q_{vj} are the balanced flows of the j pipes, in m^3/s .

I_o is the total electrical current intensity;

I_j are the balanced electrical current intensities in the j conductors;

E is the economic factor.

The optimization mathematical method are based on the relation of the multicriterial complex K , the equivalent yearly costs:

$$K = \sum_1^c (p_1 + \beta) * I_c + (p_2 + \beta) * I_p + eTP \quad (4)$$

where the first term represents the indirect operation cost and the second, the yearly energie cost. In the relation (4) aer used the notations:

p_1 - amortization rate for pipes;

p_2 - amortization rate for pump station;

β - accumulation and benefits yearly rate;

I_c - network investments cost;

I_p - pump station investments costs;

e - energy cost, in c.u./kWh;

T - operation time at maximum load, in h/y;

P - maximum load, in kW.

The economic factor E is defined by different relations, (5) for water and thermal networks,

$$E = 9,81mk \frac{[(\beta + p_2)fr + eT]}{\eta B \alpha (\beta + p_1)} \quad (5)$$

(6) for gas networks,

$$E = \frac{9,81}{1000\eta} 5Tk \frac{e}{B \alpha} \quad (6)$$

and (7) for electrical networks

$$E = k\rho \frac{[(\beta + p_2)f + eT]}{\eta B \alpha (\beta + p_1)} \quad (7)$$

where:

f is the specific installation cost;

B is the unitar cost of the pipes/conductors.

In the first effective applications [3,5], in all technical networks, optimization software [7-15], this method is considered to be a correct and a useful one, qualified as a fundamental method [55]. This method has been studied and compared to the other methods, in a new optimization cycle of water supply, gas, heating and electrical networks [37-47]. It has been evaluated as compared to other objectives of optimal solutions [70-72]and applied in most research-design contracts.

The study of the electro-hydrodynamic analogy [76] opened the way for electrical networks balancing. Other paper [16] presents the virtual transitions and the relations used for optimizing through iterations of fluid networks. In the [13,15] papers are presented the optimization relations of the electrical networks. The value of the sizing parameters at the arborescent networks pipes are $x_j = 1$.

In the Table 1 are presented the real parameters and the virtual transitions used in the optimization calculus of the fluids, respectively of the electrical networks and the relations of cycle corrections in two considered balancing methods of the closed loop networks.

Iterations balancing of the closed loop networks

Table 1

Crt. nr.	Fluid networks		Electrical networks	
	Real parameters	Virtual transitions	Real parameters	Virtual transitions
1.	$a_j = \frac{k_j}{D_j^m}$ -specific hydraulic resistance	$a_{vj} = \sqrt{ Q_j }$ -virtual specific hydraulic resistance	$\frac{\rho_j}{s_j}$ - specific electrical resistance [Ω/m]	$a_{vj} = \sqrt{ I_j }$ - virtual specific electrical resistance
unoriented parameters				

2.	$M_j = L_j a_j$ -hydraulic resistance module	$M_{vj} = L_j a_{vj}$ - virtual hydraulic resistance module	$R_j = \rho L_j / s_j$ - electrical resistance [Ω]	$M_{vj} = L_j a_{vj}$ - virtual module of electrical resistance
oriented parameters				
3.	Q_j - real volume flow of j pipe	x_j - sizing parameter of j pipe	$I_j; (P^2 + Q^2) / \sqrt{3U}$ - electric current intensity	x_j - sizing parameter of j conductor
oriented parameters				
4.	$h_j = M_j Q_j^2$ - hydraulic miscarriage	$h_{vj} = M_{vj} x_j^{-0,75}$ - virtual hydraulic miscarriage	$\Delta U_j = \frac{\sum (p_k R_k + q_k X_k)}{U_n}$ - voltage drop (three-phase lines)	$\Delta U_{vj} = M_{vj} x_j^{-0,5}$ - virtual voltage drop on a line
oriented parameters				
5.	$Q_j h_j = M_j Q_j^3$ -energetical product	$x_j h_{vj} = M_{vj} x_j^{0,25}$ - virtual power	$L_j I_j; (R_j I_j)$ - rigidity product	$L_j x_j$ - virtual rigidity product
unoriented parameters				
Calculation method relations of cycle corrections Method I of balancing				
Stage 1	$\Delta Q_i = -\frac{\sum_{(i)} \varepsilon_j L_j Q_j^2}{2 \sum_{(i)} L_j Q_j}$		$\Delta I_i = -\frac{\sum_{(i)} \varepsilon_j L_j I_j}{\sum_{(i)} L_j}$	
Stage 2	$\Delta x_i = +\frac{4}{3} \frac{\sum_{(i)} \varepsilon_j M_{vj} x_j^{-0,75}}{\sum_{(i)} M_{vj} x_j^{-1,75}}$		$\Delta x_i = -2 \frac{\sum_{(i)} L_j x_j^{-0,5}}{\sum_{(i)} L_j x_j^{-1,5}}$	
Method II of balancing				
Stage 1	$\Delta x_i = +\frac{\sum_{(i)} \varepsilon_j M_{vj} x_j^{-1}}{\sum_{(i)} M_{vj} x_j^{-2}}$		$\Delta x_i = \frac{\sum_{(i)} L_j x_j^{-1}}{\sum_{(i)} L_j x_j^{-2}}$	
Stage 2	$\Delta Q_i = -2 \frac{\sum_{(i)} L_j x_j^{-0,75} Q_j ^{0,5}}{\sum_{(i)} L_j x_j^{-0,75} Q_j ^{-0,5}}$		$\Delta I_i = \frac{\sum_{(i)} \varepsilon_j L_j x_j^{-0,5} I_j}{\sum_{(i)} L_j x_j^{-0,5}}$	

The fluid networks with at least one ring formed by the interconnection of the pipes and nodes are considered closed loop networks. The flows/electrical current intensities depend on the pipes/conductors diameters/sections.

The unknown parameters are the flows Q_j /electric current intensity I_j in each pipe/conductor which must be balanced through successive iterations and the diameters for each pipe/conductor which will be sizing in economical optimized solution.

In a network with n nodes, the partial derivatives of the optimizing criteria $\frac{\partial K}{\partial h_j}$ can be equalised with

zero for a number of $(n-1)$ values of the head losses h_j , considered like independent quantities. From the

optimising conditions results that the x_j values and the flows/intensities must be balanced in nodes.

Analytic, the mathematical system can't be solved, because the remained equations are in implicate form:

$$f(i) = \sum_{j=1}^i Q_j^{\alpha+m} x_j^{-\frac{m}{\alpha+m}} = 0 \quad (8)$$

A first model, [35], was elaborated from the condition of the minimum energetical content of the real transitions in each ring

$$\sum_i h_j Q_j = \sum_i M_j Q_j^2 Q_j \quad (9)$$

or a model with appropriate values

$$\sum_i L_j Q_j^3 = \text{minim} \quad (10)$$

For the sizing of the closed loop networks, there are three methods of balancing proposed.

In the first method, initial is proposed an arbitrary distribution of the flows $\{Q_j\}$ /electrical current intensities $\{I_j\}$ independently of the $\{x_j\}$ distribution [35]. This values are corrected through successive iterations on the base of cycle corrections ΔQ_j . In the second stage it is proposed an arbitrary $\{x_j\}$ distribution, which also must be balanced through iterations.

In the second method, [5], first the distribution of $\{x_j\}$ is balanced, independently of the $\{Q_j\}/\{I_j\}$ distribution, and than the distribution of $\{Q_j\}/\{I_j\}$ through successive iterations.

At the application of the third method of balancing [8,15], the proportionality method of the dimensioning parameters, the calculus values are obtained direct through the balancing of the flows/ electrical current intensities on the base of lengths, through the balancing of $L_j Q_j^2$ transitions.

The analytical relationship of the sizing parameter x_j is

$$x_j = \Phi Q_j \quad (11)$$

for fluid networks and

$$x_j = \Phi I_j \quad (12)$$

for electrical networks.

Once the optimized distributions $\{Q_j\}$ and $\{x_j\}$ known, the sizing relation for water and thermal networks is

$$D_j = \left(E x_j Q_p \right)^{\frac{1}{\alpha+m}} Q_j^{\frac{2}{\alpha+m}}, \quad (13)$$

for gas networks is

$$d_j = x_j^{\frac{1}{\alpha+m}} E^{\frac{1}{\alpha+m}} q_{vo}^{\frac{1}{\alpha+m}} q_{vj}^{\frac{2}{\alpha+m}} \quad (14)$$

and for electrical networks

$$s_j = \left(E I_0 I_j x_j \right)^{\frac{1}{\alpha+m}} \quad (15)$$

where s_j is the section of the electrical conductor.

In the arborescent networks, the flows in the j pipes are known and does not depend on the pipes diameter.

In a network with n nodes, from the $(n-1)$ equalised with zero equations of the head losses results the relationship:

$$D_j^{\alpha+m} = E Q_p Q_j^2 \quad (16)$$

The economical diameter for arborescent water networks results

$$D_j = \left(E Q_p \right)^{\frac{1}{\alpha+m}} Q_j^{\frac{2}{\alpha+m}} \quad (17)$$

and for gas networks

$$d_j = E^{\frac{1}{\alpha+m}} q_{vo}^{\frac{1}{\alpha+m}} q_{vj}^{\frac{2}{\alpha+m}} \quad (18)$$

In the applications had been used the following values of the parameters $\alpha=1,8$; $m=5,33$,

REFERENCES

[1] Anton, I., Turbine hidraulice, Facla, Timisoara, 1979;

$1/(\alpha+m)=0,14$. The economic diameters values do not depend on the pipes length.

The pressure losses for gas pipes are limited on the value

$$\Delta p = p_1 - p_2 \quad (19)$$

where:

p_1 is the outlet pressure measured at the station gas regulator;

p_2 is the necessary pressure at the entrance at the consumer regulator.

At the low pressure gas networks the unitar pressure losses are:

$$\frac{\Delta p}{L} = a q_v^2 = \frac{k}{d^5} q_v^2 \quad (20)$$

where a is the specific resistance, in

$$\left[\left(\frac{mmH_2O}{m} \right) : \left(\frac{m^3}{s} \right)^2 \right] \text{ and } k \text{ a coefficient, in}$$

$$\left[\left(\frac{mmH_2O}{m} \right) m^5 : \left(\frac{m^3}{s} \right)^2 \right].$$

For the low or medium pressure networks, the volum flow is not constant and so in the calculus are used the flow G , in m^3_N , in the standard state, divided by the average pressure value.

In the case of the networks supplied in diferent nods with the flows Q_1, Q_2, \dots, Q_n / electrical current intensities I_1, I_2, \dots, I_n , the equalities of the fractions can be written, for the j pipes of water or thermal systems

$$\frac{X_1}{Q_1} = \frac{X_2}{Q_2} = \dots = \frac{X_n}{Q_n} = \frac{1}{Q_p} = \Phi, \quad (21)$$

or for the j conductors of the electrical network

$$\frac{X_1}{I_1} = \frac{X_2}{I_2} = \dots = \frac{X_n}{I_n} = \frac{1}{I_0} = \Phi, \quad (22)$$

so that the additions $Q_0 = Q_1 + Q_2 + \dots + Q_n$ and $I_0 = I_1 + I_2 + \dots + I_n$ mut be respected.

3. CONCLUSIONS

The paper is an optimization technical and economical study of the open and closed loop networks. The optimized sizing of the networks on the base of the equivalent yearly costs criteria determines the optimal diameters independently of the lengths of the pipes/conductors. So in the sizing relationship don't occurs the lengths of the pipes/conductors.

The optimal dimensioning of the many sources supplied networks is an efficient method because, through the application of the virtual fluxes components proportionaly with the values of the flows/electrical current intensities at sources, an optimal repartition of the calculus parameters are assured.

[2] Astrahantev, D., Model matematic si program pentru optimizarea retelelor de apă, Teză de doctorat, 1976;

- [3] Blitz, M., Pop, R. Hidraulica, constructii hidrotehnice, alimentări cu apă, E.D.P. Bucuresti, 1961;
- [4] Borza, I., Brata, S., Optimized Redistribution of Primary Thermal Agent, Buletinul UPT, Tom 36 (50), 1991;
- [5] Brata, S., Contribuții la calculul și optimizarea rețelelor termice ca structuri inelare, Teză de doctorat, Timișoara, 1997;
- [6] Brata, S., Termotehnică, Îndrumător de proiectare, UP Timisoara, 1997;
- [7] Brata, S., Program pentru verificarea rețelelor de încălzire ca structuri inelare, Conf. Instalațiile pentru Construcții și Economia de Energie, Iași, 1991;
- [8] Brata, S., Dimensionarea optimizată a rețelelor electrice de joasă tensiune, Revista Tehnica Instalațiilor, 4/2003;
- [9] Brata, S., Calculul rețelelor de distribuție a gazelor la joasă presiune, Conf. I.C.C.A., Timișoara, 2004;
- [10] Brata, S., Jura, C., Consideratii privind optimizarea rețelelor de distribuție a energiei electrice la joasă tensiune, buletinul UPT, Tom 48(62) – 1/2003;
- [11] Brata, S., Jura, C. Probleme ale optimizării rețelelor de repartiție a gazelor, Conf. ICCA Timisoara, 1997;
- [12] Brata, S., Jura, C. Probleme ale optimizării structurii rețelelor de repartiție a gazelor la medie presiune, Conf. I.C.E.E, Iași, 2006;
- [13] Brata, S., Jura, C. Optimized Drawing of the Technical Networks Working in Closed Circuit, Scientific Bulletin of "Politehnica" University of Timisoara, Transactions on Hydraulics, Tom 51 (65), 2006, Fasc. 1,2 p. 55-58;
- [14] Brata, S., Jura, C., Efficient Analytical Methods for Optimized Dimensioning of the Technical Networks for Fluids Distribution, Scientific Bulletin of "Politehnica" University of Timisoara, Transactions on Hydraulics, Tom 51 (65), 2006, Fasc. 1,2p.59-62;
- [15] Brata, S., Jura, C., Elaborarea si optimizarea metodelor de optimizare a rețelelor electrice, Tehnica Instalatiilor nr. 7/2006;
- [16] Brata, S., Jura, C., Optimizarea rețelelor de distribuție a fluidelor prin echilibrarea inelare constructive si functionale, Conf. ICCA, Timișoara, 2006;
- [17] Brata, S., Jura, D., Asigurarea optimă a resurselor de apă si de energie în noile centre industriale, Sesiunea Jubiliară Timisoara, 1995;
- [18] Cioc, D. si colab., Hidraulică, Culegere de probleme, E.D.P., București, 1973;
- [19] Ciomocos, T., Considerente de separarea rețelelor de alimentare cu apă potabilă si industrială, Teză de doctorat, 1984;
- [20] David, I. Hidraulica, Vol. I,II, I.P.Timișoara, 1984;
- [21] Diacon, A, Seteanu, I., Popa, R. Model determinist generalizat pentru exploatarea centralelor hidroelectrice, Energetica, 11/1975;
- [22] Dobre, S., Electrotehnică și mașini electrice, I.P.Timișoara, 1982;
- [23] Dumitrescu, L. Instalații sanitare pentru ansambluri de clădiri, Ed. Tehnică, București, 1980;
- [24] Filimon, E., Brata, S., Asupra instalatiilor analogice pentru verificarea rețelelor inelare, Simpozion Baia Mare, 1985;
- [25] Filimon, E., Contributii la calculul rețelelor de apă, Teză de doctorat 1985;
- [26] Gheorghe, G. Distribuția și utilizarea gazelor combustibile, Ed. Tehnică, București, 1972;
- [27] Giurconiu, M., Hidraulică, lucrări edilitate si instalatii sanitare E.D. P. Bucuresti, 1972;
- [28] Gheorghiu, V., Contributii la studiul efectului de formă la sectiuni cu aceeasi rază hidraulică, Academia Română, Baza Timisoara, V/1958;
- [29] Hâncu, S. Hidraulică aplicată. Simularea numerică a mișcării nepermanente a fluidelor, Editura Tehnică, București, 1992;
- [30] Iacobescu, Gh. și colab. Rețele electrice. Probleme, E.D.P., București, 1981;
- [31] Ion, M., Consideratii privind calculul numeric al debitelor în castele de chilibră cu diafragmă si camera superioară, Teză de doctorat, 1989;
- [32] Ionescu, T. Grafuri. Aplicații I, II, Ed. Tehnică, București, 1973;
- [33] Ionescu, T., Pop, O. Ingineria sistemelor electrice de distribuție a energiei electrice, Editura Tehnică, Bucuresti, 1998;
- [34] Jura, C., Curs de economia apelor, Editura Didactică si Pedagogică Bucuresti, 1972;
- [35] Jura, C., Curs de alimentări cu apă, I.P. Timișoara, I/1975, II/1985;
- [36] Jura, C., Asupra determinării caracteristicilor adimensionale, ale rețelelor prin program, Buletin I.P.Timișoara, 32(36), 1977;
- [37] Jura, C., Brata, S. Dimensionarea rețelelor electrice trifazate buclate cu metoda tranzițiilor virtuale, Conferința I.C.C.A., Timișoara, 2005;
- [38] Jura, C., Brata, S., Metode analitice eficiente pentru dimensionarea rețelelor electrice alimentate din surse multiple, Tehnica Instalatiilor, 2008;
- [39] Jura, C., Brata, S. Dimensionarea optimizată a rețelelor de distribuție a gazelor combustibile, Conferinta I.C.C.A., Timișoara, 2007;
- [40] Jura, C., Brata, S, Aplicarea unei metode de dimensionare în solutie unică a rețelelor de apă inelare, Buletinul UP Timisoara, Tom 48(62), 2004;
- [41] Jura, C., Brata, S. Dimensionarea rețelelor de distribuție a gazelor combustibile, Conferinta cu participare internațională I.C.C.A., Timișoara, 2006;
- [42] Jura, C., Filimon, E., Probleme ale folosirii calculatoarelor la dimensionarea rețelelor de apă, Buletinul I.P.Timisoara, Tom 19-1/1974;
- [43] Jura, C., Filimon, E., Jura, D., Ridicarea eficienței energetice a rețelelor de apă, Conferința Energetică București, 1986;
- [44] Jura, C., Jura, D., Probleme ale optimizării lucrărilor edilitare Buletinul I. C. București XX, 3-4, 1977;
- [45] Jura, C., Jura, D., Optimisation of Water Delivery System, Buletinul I.P.T. Tom 26(39)- 1/1979;
- [46] Jura, C., Jura, D., Program pentru dimensionarea rețelelor de distribuție a apei, Conferinta a III-a, Lucrări Edilitare, Arad, 1978;
- [47] Jura, C., Jura, D., Dimensionarea optimizată a sectoarelor conductelor de transport gravitațional al apei cu alimentare pe parcurs a unui sistem regional, Hidrotehnica, nr. 8-9/2009;
- [48] Jura, D., Considerații asupra caracteristicilor calitative ale apei în sistemele hidrotehnice, Conf. ICCA, Timișoara, 1984;
- [49] Jura, D., Algoritm și program de calcul pentru exploatarea optimizată a centralelor hidroelectrice de acumulare. Conf. de Mașini Hidraulice și Hidrodinamică, Timișoara, 1985.
- [50] Jura, D., Elaborarea unui program de calcul pentru optimizarea exploatării hidroenergetice, Simpozion, Lucrări hidroedilitare, București, 1987;
- [51] Jura, D., Optimizarea exploatării centralelor hidroelectrice cu aplicare la bazinul Riul-Mare Retezat și încadrarea optimă a centralelor hidroelectrice cu acumulare din România. Teza de doctorat, 1991.
- [52] Jura, D., Brata, S., Asigurarea optimă a surselor de apă și de energie în noile centre industriale, Sesiunea jubiliară Timișoara, 1995;
- [53] Jura, D., Brata S, Situația actuală și de perspectivă a resurselor de apă, Conf. ICCA, Timișoara, 1992;
- [54] Jura, D. Jura, C., Studiu privind exploatarea optimă a centralelor hidroelectrice cu acumulare, Hidrotehnica nr. 4-5, 2009;
- [55] Matheescu, Th., Profire, M., Pop, A., Ceasca, T., Conducte din mase plastice pentru sisteme de utilități urbane, REVVOX – Bistrița, 2002.
- [56] Mănescu, A, Sandu, M., Ianculescu, O., Alimentări cu apă. Probleme, E.D. București, 1984;
- [57] Mirel, I., Alimentări cu apă și canalizări, U.T.T. 1992;
- [58] Nicoară, T., Hidraulică, Vol. I, II, Timișoara, 1986;
- [59] Nicolau, P., Laboratorul de Hidrotehnică al Facultății de Construcții, Hidrotehnica, 1/1961;
- [60] Nicolau, P., Wehry, A., Cercetări de laborator asupra unor deversoare în sifon, Hidrotehnica 9/1960;
- [61] Oancea, N., Termotehnică și aparate termice, U.P.Timișoara, 1989;
- [62] Oancea, N, Brata, S., Termotehnică și aparate termice; Îndrumător de proiectare, I.P.Timișoara, 1986;
- [63] Pavel, D. Necesitatea optimizării raportului dintre lucrările de protecție împotriva viiturilor și volumele utile ale lacurilor, Hidrotehnica, 4/1973;